



编号: XHJL-BG-08

无锡市新环化工环境监测站 检测报告 Monitoring Test Report

(2021) 环 检 (SZ) 字 第 (C21081201) 号

(水 质)

Water Quality Monitoring Report

检测类别

Project Type

委托检测

委托单位

Client Name

常州特拉奇环保科技有限公司

二〇二一年八月十三日

检测报告说明

(Test report description)

- 一、对本报告检测结果如有异议者, 请于收到报告之日起十天内向本站提出, 逾期不予受理;
If there is any objection to the test results of this report, please submit it to the site within 10 days from the date of receipt of the report.
- 二、报告需经批准人签字, 并加盖本站检测专用印章及骑缝章, 否则报告无效;
The report shall be signed by the approver and stamped with the special seal of the station and stamped at the place where the pages meet when it is over two pages, otherwise the report shall be invalid.
- 三、本报告只对本站采集的样品的检测结果负责, 对委托送检的样品仅对送检样品的检测结果负责;
This report is only responsible for the test results of the samples collected by this station. The samples submitted for inspection are only responsible for the test results of the samples submitted.
- 四、未经本站书面批准, 不得增删涂改或复制检测报告, 经同意复制的检测报告应全文复制并加盖本公司检测专用章后方有效;
The test report shall not be added or deleted without the written approval of the site, and the test report approved by the copy shall be valid after copying and stamping the company's special inspection certificate.
- 五、本报告未经同意不得用于仲裁。如申请仲裁检测, 客户须特别说明;
This report may not be used for arbitration without consent. If applying for arbitration testing, the client must specify.
- 六、检测结果“ND”表示低于方法检出限, 同时给出方法检出限。若检测结果高于检出限时, 直接报告结果;
The test result "ND" indicates that the method detection limit is lower than the method detection limit. If the test result is higher than the limits, results should be reported directly.
- 七、本报告涂改无效。
This report is invalid after being altered.

无锡市新环化工环境监测站

水质检测报告

委托单位 Client Name	常州特拉奇环保科技有限公司		地址	江苏省常州市武进区礼嘉镇工业园区于家路 3 号				
联系人 Contact Names	靳伟	电话	13961217740	邮 编	213000			
样品类别 Sample criteria	雨水							
采(送)样单位 Sample Collected (Delivered) By	无锡市新环化工环境监测站							
采(送)样人 Sample Collector (Deliverer)	姚振华 樊佳冬	采样日期 Collecting Date	2021.8.12					
检测人员 Monitoring Personal	安芳芳、还颖等	分析日期 Testing Date	2021.8.12-8.13					
检测目的 Monitoring Objectives	为客户了解污染物排放情况提供检测数据							
检测内容 Monitoring Content	化学需氧量 (COD _{Cr}) 悬浮物 (SS)							
检测结果 Monitoring Results	见 (1) 检测结果统计表							
技术说明 Monitoring Instruction	见 (2) 检测依据和所用设备							
结论 Monitoring Summary	详见数据							

编制

Prepared By

赵丹丹

复核

Checked By

马 燕

审核

Verified By

马小燕

签发

Issued By

朱晓芳

检测单位公章

Official Seal

签发日期 2021 年 8 月 13 日
Date



检测结果

(1) 检测结果统计表

采样地点 样品编号	样品状态	检测项目 单位: mg/L	
		COD _{Cr}	SS
雨水排放口	较黄较浑	48	23
以下空白			
《污水综合排放标准》 (GB8978-1996) 表 4 中 一级标准		100	70
备注		1、采样时间: 8月12日 8:05 2、本次雨水排放口中的化学需氧量、悬浮物标准限制依据《污水综合排放标准》 (GB8978-1996) 表 4 中一级标准。	

(2021)环检(SZ)字第(C21081201)号

页码(Page): 第5页共5页

(2) 检测依据和所用设备

序号	检测项目	检测分析方法	仪器名称及型号	仪器管理编号	方法检出限
1	化学需氧量	《水质 化学需氧量的测定 重铬酸盐法》HJ828-2017	50mlA 级 酸式滴定管	HX036	4mg/L
2	悬浮物	《水质 悬浮物的测定 重量法》 GB/T11901-1989	电子天平 AL104/00 电热鼓风干燥箱 GZX-GF-101	LX001 HX049	/

以下空白

